

Controller Models

EVCB14NIT0X

(0 TRIACS / independent / external motor)
For use with external floating or modulating actuators

EVCB14NIT4X

(4 TRIACS / independent / external motor)
For use with external floating or modulating actuators

EVCB14NDT4X

(4 TRIACS / dependent / external motor) For use with external floating or modulating actuators

TRL Series Digital Room Sensor

TRL24 (With temperature sensor)

TRLH24 (With temperature and humidity sensor)
TRLG24 (With temperature and CO₂ sensor)
TRLGH24 (With temperature, CO₂ and humidity

sensors)

TDU Series Digital Room Sensor

TDU00 (Vertical Grey LCD, white enclosure)
TDU30 (Vertical Black LCD, black enclosure)
TDU60 (Vertical Black LCD, white enclosure)

TDU10 (Horizontal Grey LCD, white enclosure)
TDU40 (Horizontal Black LCD, black enclosure)
TDU70 (Horizontal Black LCD, white enclosure)

Description

The EVCB Series is a combination controller and digital room sensor with support for networked communications via the BACnet MS/TP or Modbus protocol. The EVCB Series controller is compatible with both TRL24 and TDU series digital room sensors. The Networkable VAV Controller is designed for simple and accurate control of any variable air volume box in a number of zone control configurations. Its field configurable algorithms enable versatile implementation of required control sequences.

Features

- Field configured VAV algorithms, inputs and outputs
- Control external actuators using analog (0-10Vdc, adjustable) or floating signals with feedback
- On-board differential pressure sensor
- Select direction on analog outputs
- Simple air balancing and commissioning via digital room sensor
- Configurable PI (Proportional-Integral) function
- Independent, configurable proportional control band and dead band per ramp
- Activate output with CO₂ sensor from TRL/TDU or external input
- Selectable internal or external temperature sensor (10ΚΩ)
- Changeover by contact or external temperature sensor
- Internal and external temperature sensor calibration
- Freeze protection
- Removable, raising clamp, non-strip terminals

Operational Features

- Backlit LCD with simple icon and text driven menus
- · Select digital room sensor's default display
- Network service port via on-board mini USB connector
- Manual night setback or no occupancy override
- Multi level lockable access menu and setpoint
- Selectable Fahrenheit or Celsius scale
- 3-wire connection to controller and 4 push keys

Networkable VAV Controller

Specification and Installation Instructions



EVCB Series







TRL24 Series

TDU00 / TDU30 / TDU60 Series

TDU10 / TDU40 / TDU70 Series

Network Communication

- BACnet MS/TP or Modbus communication port
- Select MAC address via DIP switch or via network
- Automatic baud rate detection

BACnet MS/TP®

- Automatic device instance configuration
- Copy & broadcast configuration via digital room sensor menu or via BACnet to other controllers
- BACnet scheduler
- Firmware upgradeable via BACnet
- Support COV (change of value)

Modbus

- Modbus @ 9600, 19200, 38400 or 57600 bps
- RTU Slave, 8 bits (configurable parity and stop bits)
- Connects to any Modbus master



Specification and Installation Instructions

Controller Specifications

Description	EVCB14NIT0X, EVCB14NIT4X and EVCB14NDT4X				
Power consumption	10 VA max				
Power supply	22 to 26 Vac 50/60 Hz				
lanuta	2 Universal inputs (Thermistor 10KΩ Type 3, digital 24Vac/dry contact, or 0-10Vdc)				
Inputs	2 digital inputs				
	2 analog outputs (0-10 Vdc or 2-10Vdc; selectable)				
Outputs	Up to 4 TRIAC outputs 24 Vac, 500mA max thermal fuse in series with each TRIAC output (on/off, pulse, or 2 floating outputs)				
Real Time Clock	Real-time clock (RTC) with super capacitor backup (approximately 3 days)				
BACnet	BACnet® MS/TP @ 9600, 19200, 38400 or 76800 bps (BAS-C)				
Modbus	Modbus RTU slave @ 9600, 19200, 38400 or 57600. Selectable parity and stop bit configuration: No parity, 2 stop bit Even parity, 1 stop bit Odd parity, 1 stop bit				
Communication connection	Low capacitance, EIA RS-485, 22 or 24 AWG shielded twisted pair multi-strand cables (Belden 9841 or equivalent).				
Digital Room Sensor connection	Insulated 3 core multi-strand 22 or 24 AWG cable. Maximum 50ft (15m) between controller and digital room sensor.				
Electrical connection	Insulated 2 core 0.8 mm ² [18 AWG] minimum power cable.				
Operating temperature	0°C to 50°C [32°F to 122°F]				
Storage temperature	-30°C to 50°C [-22°F to 122°F]				
Relative Humidity	5 to 95% non condensing				
Weight	1.8 kg. [4 lb]				
Dimensions A = 7.20" 183mm B = 1.23" 31mm C = 2.93" 74mm D = 4.02" 102mm E = 1.78" 45mm	D C C				
	B B				



Specification and Installation Instructions


Digital Room Sensor Specifications

Description	TRL24 and TDU Series				
Temperature Sensor (TRL24	ensor (TRL24 and TDU)				
Setpoint range	10°C to 40°C [50°F to 104°F]				
Control accuracy	Femperature: ±0.4°C [0.8°F]				
Display resolution	±0.1°C [0.2°F]				
Humidity Sensor (TRLH24, TF	RLGH24 and TDU models with Humidity Sensors)				
Sensor range	5 to 95%RH				
Display resolution	0.1%				
CO ₂ Sensor (TRLG24, TRLGH	24 and TDU models with CO₂ Sensors)				
Operating principle	Self-calibrating, Non-Dispersive Infrared (NDIR)				
Sensor Range	0 to 2000 ppm				
Setpoint range	100 to 2000 ppm				
Accuracy	±30 ppm ±3% of reading				
Response time	2 minutes by 90%				
Display resolution	1 ppm				
PIR Motion Sensor (TDU00 / 1	TDU30 / TDU60 models with PIR Sensor)				
Operating Principle	Passive Infrared (PIR)				
Detection Angle	100°				
Detection Distance	lm [13ft]				
Detection Area	4m (13ft) 100°				
VOC Sensor (TDU00 / TDU30	/ TDU60 models with VOC Sensor)				
Operating Principle	Self-calibrating, Non-Dispersive Infrared (NDIR)				
Sensor Range	0-1000 ppb isobutylene equivalent tVOCs				
Response Time	<5 seconds for tVOC				
Start up Time	15 minutes				
Other					
Electrical connection	3 wires to VAV controller and 2 wires to BACnet/Modbus network 0.8 mm² [18 AWG] minimum				
Network service port	Mini USB connector				
Power supply	24Vac				
Power consumption	1VA				
Operating temperature	0°C to 50°C [32°F to 122°F]				
Storage temperature	-30°C to 50°C [-22°F to 122°F]				
Relative humidity	5 to 95 % non condensing				
Enclosure protection	IP 30 (EN 60529)				
Weight	120 g. [0.25 lb]				
	•				



Specification and Installation Instructions

Dimensions





Specification and Installation Instructions

TDU Models

Horizontal Model#	Temp	RH	CO ₂
TDU10-100 TDU40-100 TDU70-100	•		
TDU10-101 TDU40-101 TDU70-101	•	•	
TDU10-102 TDU40-102 TDU70-102	•	•	•
TDU10-103 TDU40-103 TDU70-103	•		•







TDU10 Series

TDU40 Series

TDU70 Series

Vertical Model #	Temp	RH	CO ₂	PIR	voc
TDU00-100 TDU30-100 TDU60-100	•				
TDU00-101 TDU30-101 TDU60-101	•	•			
TDU00-102 TDU30-102 TDU60-102	•	•	•		
TDU00-104 TDU30-104 TDU60-104	•			•	
TDU00-105 TDU30-105 TDU60-105	•	•		•	
TDU00-106 TDU30-106 TDU60-106	•	•	•		•
TDU00-107 TDU30-107 TDU60-107	•	•	•	•	•
TDU00-108 TDU30-108 TDU60-108	•	•	•	•	







TDU00 Series

TDU30 Series

TDU60 Series




Specification and Installation Instructions

TRL24




Cooling ON A: Automatic	Communication Status	Alarm status
Heating ON A: Automatic	Menu Locked	Energy saving mode (NSB or Occupancy)
Fan ON A: Automatic	Programming mod (Technician settin	
		°C _{or} °F °C: Celsius scale °F: Fahrenheit scale

TDU10 / TDU40 / TDU70 Series



$\langle \downarrow \uparrow \rangle$	Network Communication	6	User Lock	*	Programming Mode (Technician Setting)
A	Alarm Status)	Energy Saving Mode (NSB/OCC)	1234567	Schedule
8888 [£] M	Time	ррт	Parts Per Million	℃ °F %RH	°C: Celsius Scale °F: Fahrenheit Scale %RH: Humidity
А	Automatic Mode	*	Cooling	0	Heating
				~	Fan

TDU00 / TDU30 / TDU60 Series



<u>(11)</u>	Network Communication	6	User Lock	*	Programming Mode (Technician Setting)
\triangle	Alarm Status)	Energy Saving Mode (NSB/OCC)	АМ РМ	Time
℃ °F %RH	°C: Celsius Scale °F: Fahrenheit Scale %RH: Humidity	А	Automatic Mode	**	Cooling
7	Heating	3	Fan		



Specification and Installation Instructions


Mounting Instructions

TRL24



CAUTION: Remove power to avoid a risk of malfunction.

- A. Remove the captive screw that's holding the base and the front cover of the unit together.
- B. Lift the front cover of the unit to separate it from the base.
- C. Pull all wires through the holes in the base.
- D. Secure the base to the wall using wall anchors and screws (supplied). Make the appropriate connections.
- E. Mount the control module on the base and secure using the screw.




TDU10 / TDU40 / TDU70 Series



CAUTION: Remove power to avoid a risk of malfunction.

- A. Remove the wall mounting plate (highlighted) from the back of the digital room sensor.
- B. Install the mounting plate on the gang box.
- C. Pull the wires through the base hole and make the appropriate connections.
- D. Mount the digital room sensor onto the wall plate. To mount it, place the top of the digital room sensor on the mounting plate first and push it into the grooves to snap it into place.
- E. Secure the digital room sensor using the screw (supplied).




TDU00 / TDU30 / TDU60 Series



CAUTION: Remove power to avoid a risk of malfunction.

- A. Remove the captive screw that's holding the base and the front cover of the unit together.
- B. Lift the front cover of the unit to separate it from the base.
- Pull all wires through the holes in the base.
- D. Secure the base to the wall using wall anchors and screws (supplied). Make the appropriate connections.
- E. Mount the control module on the base and secure using the screw.





Specification and Installation Instructions


Mechanical Installation- Actuator

- Manually close the damper blades and position the actuator to 0° or 90°.
- 2. Slide the actuator onto the shaft.
- 3. Tighten the nuts on the "U" bolt to the shaft with an 8mm wrench to a torque of 150 in.lb. [17 Nm].
- Slide the mounting bracket under the actuator. Ensure free movement of the slot at the base of the actuator. Place the bracket pin at mid distance of the slot.
- Affix the bracket to the ductwork with #8 self-tapping screws.
- Connect the cable from the EVC to the terminal in the actuator as shown.




Do not press the clutch when the actuator is powered.

Terminals on the Actuator




External 180 in. lb. Actuator



Signal cable from EVC controller

Use to connect the external motor on EVCB14NIT0X EVCB14NIT4X and EVCB14NDT4X.



BACnet or Modbus Address DIP Switch (DS1)

MAC address for communication, are selectable by DIP switch using binary logic. If you do not change device instance in program mode, it will be automatically modified according to the MAC address.



Note: Avoid using addresses above 246 when selecting Modbus MAC address.

MAC Address	DS.1 = 1	DS.2 = 2	DS.3 = 4	DS.4 = 8	DS.5 = 16	DS.6 = 32	DS.7 = 64	DS.8 = 128	Default Device Instance
0	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	153000
1	ON	OFF	OFF	OFF	OFF	OFF	OFF	OFF	153001
2	OFF	ON	OFF	OFF	OFF	OFF	OFF	OFF	153002
3	ON	ON	OFF	OFF	OFF	OFF	OFF	OFF	153003
4	OFF	OFF	ON	OFF	OFF	OFF	OFF	OFF	153004
126	OFF	ON	ON	ON	ON	ON	ON	OFF	153126
127	ON	ON	ON	ON	ON	ON	ON	OFF	153127


^{*} Slave addresses available by setting DS.8 to ON



Specification and Installation Instructions

Wiring

We strongly recommend that all Neptronic products be wired to a separate grounded transformer and that transformer shall service only Neptronic products. This precaution will prevent interference with, and/or possible damage to incompatible equipment.






Specification and Installation Instructions

PCB Drawings

TRL24 Digital Room Sensor

3 wire cable (TB1 #1, 2 & 3)

Connect TB1 #6 (A+) & #7 (B-) to EVCB to enable the BACnet service port.




Mode Selection (JP1)

JP1 RUN	RUN: Digital room sensor is in Operation Mode. Digital room sensor must be set in this mode for normal system operation. If not locked, setpoint and control mode can be changed by the end user.
JP1 RUN PGM	PGM: Digital room sensor is set in Programming Mode. Refer to the following sections for more details.

TDU10 / TDU40 / TDU70 Series

3 wire cable (TB1 #1, 2 & 3)

Connect TB1 #6 (A+) & #7 (B-) to EVCB to enable the BACnet service port.




Mode Selection (JP1)

JP1 RUN	RUN: Digital room sensor is in Operation Mode. Digital room sensor must be set in this mode for normal system operation. If not locked, setpoint and control mode can be changed by the end user.
JP1 RUN PGM	PGM: Digital room sensor is set in Programming Mode. Refer to the following sections for more details.

TDU00 / TDU30 / TDU60 Series

3 wire cable (TB1 #1, 2 & 3)

Connect TB1 #6 (A+) & #7 (B-) to EVCB to enable the BACnet service port.



Mode Selection (JP1)

JP1 RUN	RUN: Digital room sensor is in Operation Mode. Digital room sensor must be set in this mode for normal system operation. If not locked, setpoint and control mode can be changed by the end user.
JP1 RUN PGM	PGM: Digital room sensor is set in Programming Mode. Refer to the following sections for more details.



Specification and Installation Instructions

Access to Menus

The menu overviews and options are the same for both TRL24 and TDU digital room sensors. However, the action key or the key used to access the menus and save changes is different in the digital room sensors. Use the following menu overviews with the appropriate action key as per your digital room sensor.

Action Keys on Digital Room Sensor

Action Key		Took	
TRL24	TDU	Task	
*	D	Press to access the programming menus and save any changes.	
4		Press to return to the previous step without saving.	




Note: Prior to going into Programming Mode, remove the connection cable between the EVCB and the TRL/TDU and set the Mode Selection jumper (JP1) to PGM on the digital room sensor. Reestablish the connection in order to access the programming menus and to make any changes. Once all menu changes have been made, remove the connection cable again before setting jumper JP1 back to RUN, and then reconnect the cable to resume normal operation.



Specification and Installation Instructions

Pressure & Applications – Menu (1 of 7) | Pressure and Applications


For a description of the default settings for each application refer to Annex A: Control Apps on page 23.







Inputs - Menu (2 of 7) | AI1, AI2, DI1 and DI2




Page | 13 www.neptronic.com



Specification and Installation Instructions


TRIAC Outputs - Menu (3 of 7) | TO1 to TO4





Specification and Installation Instructions


Analog Outputs - Menu (4 of 7) | AO1 and AO2





Specification and Installation Instructions


Settings - Menu (5 of 7) | Temp, Motor, and Settings





Specification and Installation Instructions

Settings - Menu (6 of 7) | Ramps, Network and Time



Specification and Installation Instructions

Settings – Menu (7 of 7) | Buttons and Options

Main Menu Sub Menu Configuration

*** To save any changes, press on TRL and on TDU ***

*** To the previous step without saving, press on TRL and TDU ***

▲▼= scroll menu items Main Menu PrSs (Pressure) ▲▼= select/set value go to "OPt" BOTTOM LEFT KEY LOCKED UPPER LEFT KEY LOCKED ARROWS KEY LOCKED APPS (Applications) NO NO NO • YES YES YES 0 Ö 0 InPt (Inputs) Appears only if using TRLG or TRLGH or Appears only if using TRLG or TRLGH or TDU digital room sensors with CO2. TDU digital room sensors with CO2. OutP (Outputs) Appears only if using digital room For digital room sensors with temperature Appears only if using digital room For digital room sensors with temperature and humidity, go to "InPt" menu. sensors with CO2. sensors with Humidity. and humidity, go to "InPt" menu. CO2 DISPLAY CO2 SETPNT CO2 CONTROL SOURCEBV.66 DISPLAY HUMDTY BV.60 -Go to "PrSs" YES 0 800 ppm YES 0 tMp (Temperature) NO ANLg NO • To display CO2 without generating an alarm, use a setpoint higher than When set to YES, the unit will not display 2000ppm or the CO₂ Maximum Range the time when in Operation Mode (highest of the 2). Mot (Motor) Setc (Settings) rMp (Ramps) **NET** (Network) HrS (Time & Date) **btN** (Buttons) OPt (Options) Only available with CO2 sensor models



Specification and Installation Instructions

Operation Menus

This menu is accessible through normal operation mode. The Mode Selector jumper (JP1) of the digital room sensor must be set to the "RUN" position (Operation Mode). Refer to Wiring on page 9.

Note: Since the action keys are different on TRL and TDU digital room sensor series, both keys have been included in the instructions. Refer to the Action Keys on Digital Room Sensor section to know and use the key as available on your digital room sensor.

- 1. Press the [🖈 / 🗓] and 🛹 keys simultaneously for 5 seconds. The "Enter Password" screen appears.
- 2. Enter the password within 1 minute by using the arrow keys to increase or decrease the value and the [* / *] and * keys to toggle between the digits.
 - a. Password **372** = Temperature Offset Menu
 - b. Password 637 = Network Settings Menu
 - c. Password **757** = Airflow Balance Mode
- 3. If you enter the wrong password, the digital room sensor displays "Eror" and returns to Operation Mode. The digital room sensor will return to normal mode if you navigate through the entire menu and do not make any selection, or if you do not press any key for 5 minutes. The changed values will be saved automatically.

Menu 372 - Temperature Offset

1. "INTERN TEMP SENSOR OFFSET"

Range: $10 \text{ to } 40^{\circ}\text{C}$ Offset: $\text{Max} \pm 5^{\circ}\text{C}$

[50 to 104°F]

Increment:

0.1°C

[0.2°F]

Compare the displayed temperature reading with a known value from a digital room sensor. To offset or calibrate the sensor, use the arrows key to set the desired temperature reading. This is useful for digital room sensors installed in areas where the temperature read is slightly different than the room's actual temperature. For example, a digital room sensor placed right under the air diffuser.

If the digital room sensor is set to use an external temperature sensor (EtS), the digital room sensor displays "OFF".

2. "EXTERN TEMPER SENSOR OFFSET"

Range: 0 to 50° C Offset: Max $\pm 5^{\circ}$ C [41 to 122°F]

Increment: 0.1° C

[0.2°F]

This option appears if you've set one of the analog inputs to **EtS** (External temperature sensor). When the digital room sensor is connected to the appropriate analog input, the display shows the temperature read by the external temperature sensor. Adjust the offset by comparing it with a known value (e.g. thermometer). If the sensor is not connected or short circuited, then the unit displays the sensor's limit.

3. "INPUT3 READING"



Range: 250mV (0") to 4000mV (1")

Displays the voltage output value in mV of the pressure sensor. Does not appear for EVCB14NDT4X (pressure dependent) model.


Ч. "INPUT3 MINIMUM READING"

Range: 10mV to 180mV

Default: 60mV

This setting represents the deadband of the pressure sensor in mV. For advanced users or special applications only. We recommend that you use the default setting of 60mV. Does not appear for EVCB14NDT4X (pressure dependent) model.

Menu 637 – Network Settings



^{***} To save any changes, press ★ on TRL and □ on TDU ***

*** To the previous step without saving, press ← on TRL and TDU ***


www.neptronic.com Page | 19



Specification and Installation Instructions

Menu 757 - Airflow Balance Mode

Pressure independent models: EVCB14NIT0X and EVCB14NIT4X




*** To save any changes, press ★ on TRL and ☐ on TDU ***
*** To the previous step without saving, press ← on TRL and TDU ***



Note: Refer to EVCB-Airflow Balance Instructions on Neptronic website for further information on airflow balancing function.

Pressure dependent model: EVCB14NDT4X



- *** To save any changes, press 🛨 on TRL and 🖵 on TDU ***
- *** To the previous step without saving, press on TRL and TDU ***

Reset to Factory Default Settings



This will erase all actual configurations and replace them with the factory default settings.

- The Mode Selector jumper (JP1) of the digital room sensor must be set to the "RUN" position (Operation Mode). Refer to Wiring on page 9.
- 2. During the power up sequence of the controller and digital room sensor, press and hold both the

 ✓ and ▼keys.
- 3. The "Enter Password" screen appears. Enter 372 within 1 minute by using the arrow keys to increase or decrease the value and the [🛨 / 🗓] and 🛹 keys to toggle between the digits.
- 4. Use the arrow keys to select YES and then press [🖈 / 🗓]




Specification and Installation Instructions


Operation Mode

The Mode Selector Jumper (JP1) of the digital room sensor must be set to the "RUN" position (Operation Mode). Refer to Wiring on page 9.


TRL24



TDU10 / TDU40 / TDU70 Series



TDU00 / TDU30 / TDU60 Series



neptronic[®]

Networkable VAV Controller

Specification and Installation Instructions

Power Up

Upon power up, the LCD illuminates and all segments appear for 2 seconds. The digital room sensor then displays its current version of the digital room sensor for 2 seconds followed by the current version of the controller for 2 seconds. Pressing any key on the digital room sensor illuminates the LCD for 4 seconds.

CO₂ (Digital Room Sensors with CO₂)

If enabled via the configuration menu, the digital room sensor displays the CO₂ reading on the first line above the temperature reading. If CO₂ display is enabled, the time will not be displayed.

Temperature Display and Setpoint

If enabled in the "Display Info" menu (see Settings – Menu (5 of 7) | Temp, Motor, and Settings on page 16), the digital room sensor displays the temperature reading. If the sensor is disconnected or short circuited, then the unit displays the sensor's limit. To toggle the temperature scale between °C and °F, press the key. To display the setpoint, press the or key twice. The setpoint appears for 5 seconds. To adjust the setpoint, press the arrow keys while the temperature is displayed. If the setpoint adjustment has been locked "Setpnt Locked", the lock be symbol appears.

Humidity

If enabled in the "Options" menu (see Settings – Menu (6 of 7) | Ramps, Network and **Time** on page 17), the digital room sensor displays the temperature reading for 8 seconds and then displays the humidity reading for 2 seconds. If the sensor is disconnected or short circuited, then the unit displays the sensor's limit.

Airflow and Air Supply Temperature

Press and hold the [** / *!] key for 5 seconds and use the arrow keys to view the "airflow", "airflow Setpnt", "actual damper pos percent" and "air Supply Temp". After 5 seconds without any action, the digital room sensor returns to operation mode. The air supply temperature appears only if analog input Al1 or Al2 are configured with the AST option. Not available on the following pressure dependent model *EVCB14NDT4X*.

Control Mode

- Auto (Automatic Cooling or Heating)
- OFF (if it is not disabled in Programming Mode)
- Cooling only (on, with cooling symbol)
- Heating only (on, with heating symbol)


Night Setback (NSB) or Occupancy Mode

This function is only available if you set DI1 to **nSb** (Night setback contact) or **Occ** (occupancy mode). If the DI1 contact is triggered, the digital room sensor enters NSB or No Occupancy Mode (the) symbol appears) and uses the NSB or OCC heating and cooling setpoints.

If not locked, you can override the night setback or no occupancy mode for a predetermined period by pressing any of the 4 keys. During the override period the $\ \ \ \ \$ symbol will flash. If the $\ \ \ \ \$ symbol does not flash, the override period is finished or the night setback or no occupancy override has been locked in programming mode.

Set Time and Date

- 1. Ensure that JP1 on the digital room sensor is set to Run.
- 2. Press and hold the 4 key for 5 seconds
- 3. Use the arrow keys to set the desired value. Press the [🛨 / 🗓] key to save and got to the next step. Press the 🖊 key to go to the previous step without saving.



^{***} To save any changes, press 🗷 on TRL and 🗓 on TDU ***

^{***} To the previous step without saving, press— on TRL and TDU ***



Specification and Installation Instructions

Annex A: Control Apps

Refer to *Pressure & Applications – Menu (1 of 7)* on page 12 for more information. The available **Control Apps** vary according to the model

Description	CL (cool only)	CLHt (cool/heat)	CHrH (cool/heat/reheat)	CO₂ (CO ₂)	ITOS (ITOS)	FPbo (fan powered ON)	FPbA (fan powered Auto)
Min. Setpoint	20°C (68°F)	20°C (68°F)	20°C (68°F)	20°C (68°F)	15°C (59°F)	15°C (59°F)	15°C (59°F)
Max. Setpoint	28°C (82°F)	28°C (82°F)	28°C (82°F)	28°C (82°F)	30°C (86°F)	30°C (86°F)	30°C (86°F)
Changeover Setpnt	24°C (75°F)	20°C (68°F)	20°C (68°F)	20°C (68°F)	24°C (75°F)	24°C (75°F)	24°C (75°F)
TO1 Ramp	HR1	CR1	HR1	CR1	OFF	HR1	HR1
TO1 Signal Type	On/Off	On/Off	On/Off	On/Off	On/Off	On/Off	On/Off
TO1 Close Pos.	40%	40%	40%	40%	40%	35%	35%
TO1 Open Pos.	0%	0%	0%	0%	0%	0%	0%
TO2 Ramp	HR1	HR1	HR1	CO ₂	OFF	HR1	HR1
TO2 Signal Type	Pulse	On/Off	Pulse	On/Off	On/Off	On/Off	On/Off
TO2 Close Pos.	40%	40%	40%	40%	40%	70%	70%
TO2 Open Pos.	0%	0%	0%	0%	0%	35%	35%
TO3 Ramp	HR2	CR2	HR2	HR1	OFF	Fan ON	Fan Auto
TO3 Signal Type	On/Off	On/Off	On/Off	On/Off	On/Off	On/Off	On/Off
TO3 Close Pos.	40%	40%	40%	40%	40%	40%	40%
TO3 Open Pos.	0%	0%	0%	0%	0%	0%	0%
TO4 Ramp	HR2	HR2	HR2	HR1	OFF	HR1	HR1
TO4 Signal Type	Pulse	On/Off	Pulse	On/Off	On/Off	On/Off	On/Off
TO4 Close Pos.	40%	40%	40%	40%	40%	40%	40%
TO4 Open Pos.	0%	0%	0%	0%	0%	0%	0%
Motor Ramp	CR1	COr	COr	COr	CR1	CR1	COr
AO1 ramp	HR1	CR1	HR1	CR1	HR1	HR1	HR1
AO2 Ramp	HR2	HR1	HR2	HR1	OFF	HR2	Fan Auto
Al1 Input	OFF	SENS	SENS	SENS	OFF	OFF	SENS
Al2 Input	OFF	OFF	OFF	CO ₂	OFF	OFF	OFF
DI1 Input	nSb.o	nSb.o	nSb.o	Occ.o	Occ.o	nSb.o	nSb.o
Heat Prop Band 2	2°C (4°F)	2°C (4°F)	2°C (4°F)	2°C (4°F)	2°C (4°F)	1°C (2°F)	1°C (2°F)
Heat Deadband 2	1.3°C (2.6°F)	1.3°C (2.6°F)	1.3°C (2.6°F)	1.3°C (2.6°F)	0.3°C (0.6°F)	1.3°C (2.6°F)	1.3°C (2.6°F)
Cool Deadband 2	1.3°C (2.6°F)	1.3°C (2.6°F)	1.3°C (2.6°F)	1.3°C (2.6°F)	0.3°C (0.6°F)	0.3°C (0.6°F)	0.3°C (0.6°F)

Legend

Grey Text = Standard default value

Bold Text = Special default value for selected application

HR = Heating ramp
CR = Cooling ramp
COr = Changeover ramp

SENS = Changeover temperature sensor Fan ON = Fan powered box in continuous mode

Fan Auto = Fan powered box in automatic mode (follows demand)

nSb.o = Night Setback (normally open) Occ.o = Occupancy mode (normally open)

TO = TRIAC output AO = Analog output AI = Analog input DI = Digital input



Recycling at end of life: please return this product to your Neptronic local distributor for recycling. If you need to find the nearest Neptronic authorized distributor, please consult **www.neptronic.com**.



neptronic

400 Lebeau blvd, Montreal, Qc, H4N 1R6, Canada www.neptronic.com

Toll free in North America: 1-800-361-2308

Tel.: (514) 333-1433 Fax: (514) 333-3163

Customer service fax: (514) 333-1091

Monday to Friday: 8:00am to 5:00pm (Eastern time)