



neptronic®

Evaporative Cooler

SKVF Series

Modbus Communication Module User Guide



Introduction

The SKVF Modbus Communication Module User Guide provides information for using Neptronic[®] communication feature. The controller uses Modbus communication protocol over serial line in the RTU mode and provides a Modbus network interface between client devices and Neptronic SKVF devices.

The SKVF Modbus Guide assumes that you are familiar with Modbus terminology.

The following are the requirements for Modbus:

- *Data Model.* The Evaporative Cooler Modbus server data model uses only the Modbus Registers table.
- *Register Address:*
 - As per protocol base (base 0); for PLC add 1 to protocol base.
 - As per holding register (base 400001).



Note: Ensure that the Modbus communication software used does not have a limit on the range of the register addresses that can be viewed and supports 6-digit holding registers.

- *Function Codes.* The Evaporative Cooler Modbus server supports a limited function codes subset comprising:
 - Read Holding Registers (0x03)
 - Write Single Register (0x06)
 - Write Multiple Registers (0x10)
- *Exception Responses.* The Evaporative Cooler Modbus server supports the following exception codes:
 - Illegal data address
 - Illegal data value
 - Slave device busy
- *Serial Line.* The Evaporative Cooler Modbus over serial line uses RTU transmission mode over a two-wire configuration RS485 (EIA/TIA-485 standard) physical layer.
 - The physical layer can use fixed baud rate selection or automatic baud rate detection (default) as per the **Modbus Auto Baud Rate** device menu item or holding register index 1.
 - The supported baud rates are 9600, 19200, 38400, and 57600.
 - The physical layer also supports variable parity control and stop bit configuration as per the **Modbus Comport Config** device menu item or holding register index 2.
 - In auto baud rate configuration, if the device detects only consecutive bad frames (2 or more) for one second with any given baud rate, it will reinitialize itself to the next baud rate.
- *Addressing.* The Evaporative Cooler device only answers at the following address:
 - The device's unique address (1 to 246) that can be set through the device menu or through holding register index 0.

Modbus Registers

Table Glossary

Name	Description	Name	Description
W	Writable Register	ASCII	For registers containing ASCII (8-bit) characters
RO	Read Only Register	MSB	Most Significant Byte
Unsigned	For range of values from 0 to 65,535, unless otherwise specified	LSB	Least Significant Byte
Signed	For range of values from -32,768 to 32,767, unless otherwise specified	MSW	Most Significant Word
Bit String	For registers with multiple values using bit mask (example, flags)	LSW	Least Significant Word

Modbus Registers Table

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writ able	Default Value
0	400001	Modbus Address and Product Type	Unsigned	MSB = Product type, not writable LSB = Modbus Address (1 to 247), writable	W	
1	400002	Device Baud Rate	Unsigned <i>Scale 100</i>	0, 9600, 19200, 38400, and 57600, 0 = Auto Baud <i>Rate Detection Value/100</i> (e.g. 38400 baud = 384)	W	19200
2	400003	Modbus Slave Communication Port Configuration	Unsigned	0 = No parity, 2 Stop bits 1 = Even parity, 1 Stop bit 2 = Odd parity, 1 Stop bit	W	No parity, 2 Stops bits
3	400004	Product Name (characters 8 & 7)	ASCII	MSB = char 6, LSB = char 7	W	
4	400005	Product Name (characters 6 & 5)	ASCII	MSB = char 4, LSB = char 5	W	
5	400006	Product Name (characters 4 & 3)	ASCII	MSB = char 2, LSB = char 3	W	
6	400007	Product Name (characters 2 & 1)	ASCII	MSB = char 0, LSB = char 1	W	

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writab le	Default Value
7	400008	Product Actual Firmware Version (in Integer x100)	Unsigned Scale 100	1 to 65535 (e.g. 100)	RO	
8	400009	Product Actual EEPROM Version (in Integer x100)	Unsigned Scale 100	1 to 65535 (e.g. 100)	RO	
2000	402001	Control Signal	Unsigned Scale 1000	Units: Volt (V), Range: 0V to 15V Value x 1000 (e.g. 2V = 2000)	RO	0V
2001	402002	Control Signal	Unsigned Scale 1000	Units: Volt (V), Range: 0V to 15V Value x 1000 (e.g. 2V = 2000)	RO	0V
2002	402003	Room RH Signal	Unsigned Scale 1000	Units: Volt (V), Range: 0V to 15V Value x 1000 (e.g. 2V = 2000)	RO	0V
2003	402004	Room Temperature Signal	Unsigned Scale 1000	Units: Volt (V), Range: 0V to 15V Value x 1000 (e.g. 2V = 2000)	RO	0V
2004	402005	Supply RH Signal	Unsigned Scale 1000	Units: Volt (V), Range: 0V to 15V Value x 1000 (e.g. 2V = 2000)	RO	0V
2005	402006	Supply Temperature Signal	Unsigned Scale 1000	Units: Volt (V), Range: 0V to 15V Value x 1000 (e.g. 2V = 2000)	RO	0V
2006	402007	ECM Fan Feedback	Unsigned Scale 1	Units: Hz, Range: 0 to 30000Hz Value x 1 (e.g. 10Hz = 10)	RO	0Hz
2007	402008	ECM Fan Feedback 2	Unsigned Scale 1	Units: Hz, Range: 0 to 30000Hz Value x 1 (e.g. 10Hz = 10)	RO	0Hz
2008	402009	Float Switch Signal	Unsigned Scale 1000	Unit: Volt (V), Range: 0V to 10V Value x 1000 (e.g. 2V = 2000)	RO	0V
2009	402010	Board Temperature Signal	Unsigned Scale 1000	Unit: Volt (V), Range: 0V to 10V Value x 1000 (e.g. 2V = 2000)	RO	0V
2010	402011	Main Power Supply	Unsigned Scale 10	Unit: Volt (V), Range: 0V to 40V Value x 10 (e.g. 2V = 20)	RO	0V

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writab le	Default Value
4000	404001	Power Output Feedback Signal	Unsigned Scale 1000	Unit: Volt (V), Range: 0V to 10V Value x 1000 (e.g. 2V = 2000)	RO	0V
4001	404002	ECM Fan Signal	Unsigned Scale 100	Unit: Volt (V), Range: 0V to 10V Value x 1000 (e.g. 2V = 2000)	RO	0V
6000	406001	Control Input	Unsigned Scale 100	Unit: %, Range: 0% to 100% Value x 100 (e.g. 10% = 1000)	W	0%
6001	406002	Control Min	Unsigned Scale 100	Unit: %, Range: 0% to 100% Value x 100 (e.g. 10% = 1000)	W	0%
6002	406003	Control Max	Unsigned Scale 100	Unit: %, Range: 0% to 100% Value x 100 (e.g. 10% = 1000)	W	0%
6003	406004	Control Bias	Signed Scale 100	Unit: %, Range: -10% to 10% Value x 100 (e.g. 10% = 1000)	W	0%
6004	406005	Control Input	Signed Scale 100	Unit: C or F, Range: -40.0°F, max: 212.0°F or -40.0°C, max: 100.0°C Value x 100 (e.g. 10% = 1000)	W	20.0°C or 68.0°F
6005	406006	Control Min	Signed Scale 100	Unit: C or F, Range: -40.0°F, max: 212.0°F or -40.0°C, max: 100.0°C Value x 100 (e.g. 10% = 1000)	W	0.0°C or 32.0°F
6006	406007	Control Max	Signed Scale 100	Unit: C or F, Range: -40.0°F, max: 212.0°F or -40.0°C, max: 100.0°C Value x 100 (e.g. 10% = 1000)	W	40.0°C or 104.0°F
6007	406008	Control Bias	Signed Scale 100	Unit: C or F, Range: -18.0°F, max: 18.0°F or -10.0°C, max: 10.0°C Value x 100 (e.g. 10% = 1000)	W	20.0°C or 68.0°F
6008	406009	Room RH	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	RO	0% RH

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writable	Default Value
6009	406010	Room RH Min	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	W	0% RH
6010	406011	Room RH Max	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	W	0% RH
6011	406012	Room RH Bias	Unsigned Scale 100	Unit: % RH, Range: -10% RH to 10% RH Value x 100 (e.g. 10% RH = 1000)	W	0% RH
6012	406013	Room Temperature	Signed Scale 100	Unit: C or F, Range: -40.0°F, max: 212.0°F or -40.0°C, max: 100.0°C Value x 100 (e.g. 10°C = 1000)	W	20.0°C or 68.0°F
6013	406014	Room Temperature Min	Signed Scale 100	Unit: C or F, Range: -40.0°F, max: 212.0°F or -40.0°C, max: 100.0°C Value x 100 (e.g. 10°C = 1000)	W	0.0°C or 32.0°F
6014	406015	Room Temperature Max	Signed Scale 100	Unit: C or F, Range: -40.0°F, max: 212.0°F or -40.0°C, max: 100.0°C Value x 100 (e.g. 10°C = 1000)	W	40.0°C or 104.0°F
6015	406016	Room Temperature Bias	Signed Scale 100	Unit: C or F, Range: -18.0°F, max: 18.0°F or -10.0°C, max: 10.0°C Value x 100 (e.g. 10°C = 1000)	W	0.0°C or 0.0°F
6016	406017	Supply High Limit RH	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	RO	0% RH
6017	406018	Supply High Limit RH Min	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	W	0% RH
6018	406019	Supply High Limit RH Max	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	W	0% RH
6019	406020	Supply High Limit RH Bias	Signed Scale 100	Unit: %, Range: -10% RH to 10% RH Value x 100 (e.g. 10% RH = 1000)	W	0% RH

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writable	Default Value
6020	406021	Supply High Limit Temperature	Signed Scale 100	Unit: C or F, Range: -40.0°F, max: 212.0°F or -40.0°C, max: 100.0°C Value x 100 (e.g. 10°C = 1000)	W	20.0°C or 68.0°F
6021	406022	Supply High Limit Temperature Min	Signed Scale 100	Unit: C or F, Range: -40.0°F, max: 212.0°F or -40.0°C, max: 100.0°C Value x 100 (e.g. 10°C = 1000)	W	0.0°C or 32.0°F
6022	406023	Supply High Limit Temperature Max	Signed Scale 100	Unit: C or F, Range: -40.0°F, max: 212.0°F or -40.0°C, max: 100.0°C Value x 100 (e.g. 10°C = 1000)	W	40.0°C or 104.0°F
6023	406024	Supply High Limit Temperature Bias	Signed Scale 100	Unit: C or F, Range: -18.0°F, max: 18.0°F or -10.0°C, max: 10.0°C Value x 100 (e.g. 10°C = 1000)	W	20.0°C or 68.0°F
6024	406025	Demand (0)	Unsigned Scale 100	Unit: %, Range: 0% to 100% Value x 100 (e.g. 10% = 1000)	W	0.0°C or 0.0°F
6025	406026	Demand (1)		Unit: %, Range: 0% to 100%		
6026	406027	Demand (2)		Unit: %, Range: 0% to 100%		
6027	406028	Demand (3)		Unit: %, Range: 0% to 100%		
6028	406029	Power Output	Unsigned Scale 100	Unit: %, Range: 0% to 100% Value x 100 (e.g. 10% = 1000)	RO	0%
6029	406030	Run Time (0)	Unsigned Scale 100	Units: Hours (h), Range: 0 to 2147483647 h Value x 100 (e.g. 10 h = 1000)	RO	0h
6030	406031	Run Time (1)		Units: Hours (h), Range: 0 to 2147483647 h		
6031	406032	Run Time (2)		Units: Hours (h), Range: 0 to 2147483647 h		
6032	406033	Run Time (3)		Units: Hours (h), Range: 0 to 2147483647 h		
6033	406034	On Time (0)	Unsigned Scale 100	Units: Hours (h), Range: 0 to 2147483647 h Value x 100 (e.g. 10 h = 1000)	RO	0h

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writable	Default Value
6034	406035	On Time (1)		Units: Hours (h), Range: 0 to 2147483647 h		
6035	406036	On Time (2)		Units: Hours (h), Range: 0 to 2147483647 h		
6036	406037	On Time (3)		Units: Hours (h), Range: 0 to 2147483647 h		
6037	406038	Water Treatment Service On Time (0)	Unsigned Scale 100	Units: Hours (h), Range: 0 to 2147483647 h Value x 100 (e.g. 10 h = 1000)	RO	0h
6038	406039	Water Treatment Service On Time (1)		Units: Hours (h), Range: 0 to 2147483647 h		
6039	406040	Water Treatment Service On Time (2)		Units: Hours (h), Range: 0 to 2147483647 h		
6040	406041	Water Treatment Service On Time (3)		Units: Hours (h), Range: 0 to 2147483647 h		
6041	406042	Service On Time (0)	Unsigned Scale 100	Units: Hours (h), Range: 0 to 2147483647 h Value x 100 (e.g. 10 h = 1000)	RO	0h
6042	406043	Service On Time (1)		Units: Hours (h), Range: 0 to 2147483647 h		
6043	406044	Service On Time (2)		Units: Hours (h), Range: 0 to 2147483647 h		
6044	406045	Service On Time (3)		Units: Hours (h), Range: 0 to 2147483647 h		
6045	406046	Dead Band	Unsigned Scale 1	Unit: %, Range: 1% to 100% Value x 1 (e.g. 10% = 10)	W	5%
6046	406047	Minimum Production Output	Unsigned Scale 1	Unit: %, Range: 0% to 100% Value x 1 (e.g. 10% = 10)	W	10%
6047	406048	Maximum Production Output	Unsigned Scale 1	Unit: %, Range: 0% to 100% Value x 1 (e.g. 10% = 10)	W	100%
6048	406049	Fan On Delay	Unsigned Scale 1	Unit: Minutes (min), Range: 0 min to 300 min Value x 1 (e.g. 10min = 10)	W	15 min
6049	406050	Dry Fan Speed	Unsigned Scale 1	Unit: %, Range: 0% to 100% Value x 1 (e.g. 10% = 10)	W	0%
6050	406051	Service Interval	Unsigned Scale 1	Units: Hours (h), Range: 1000 to 3000 h Value x 1 (e.g. 10 h = 10)	W	1000h

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writable	Default Value
6051	406052	Dilution Ratio	Unsigned Scale 1	Unit: %, Range: 0% to 150% Value x 1 (e.g. 10% = 10)	W	100%
6052	406053	Drain Interval	Unsigned Scale 1	Unit: Hours (h), Range: 0 to 24 h Value x 1 (e.g. 10h = 10)	W	4h
6053	406054	Fixed Drain Time	Unsigned Scale 1	Unit: Hours (h), Range: 4 to 72 h Value x 1 (e.g. 10h = 10)	W	6h
6054	406055	Line Rinse Time	Unsigned Scale 1	Unit: Seconds (sec), Range: 0sec to 2000sec Value x 1 (e.g. 10sec = 10)	W	180 sec
6055	406056	Water Treatment Service Interval (0)	Unsigned Scale 1	Unit: Hours (h), Range: 1000 to 3000 h Value x 1 (e.g. 10h = 10)	W	1000h
6056	406057	Water Treatment Service Interval (1)		Unit: Hours (h), Range: 1000 to 3000 h		
6057	406058	Water Supply Duty Cycle (0)	Unsigned Scale 1	Unit: %, Range: 8% to 70% Value x 1 (e.g. 10% = 10)	W	10%
6058	406059	Water Supply Duty Cycle (1)		Unit: %, Range: 8% to 70%		
6059	406060	Water Supply Period (0)	Unsigned Scale 1	Unit: Seconds (sec), Range: 0sec to 180sec Value x 1 (e.g. 10sec = 10)	W	60 sec
6060	406061	Water Supply Period (1)		Unit: Seconds (sec), Range: 0sec to 180sec		
6061	406062	Completely Dry Delay	Unsigned Scale 1	Unit: Hours (h), Range: 0 to 24 h Value x 1 (e.g. 10h = 10)	W	2h
6062	406063	Hour of Day Drying Cycle	Unsigned Scale 1	Unit: Hours (h), Range: 0 to 24 h Value x 1 (e.g. 10h = 10)	W	24h
6063	406064	Modbus TCP IP Keep Alive Time Out (0)	Unsigned Scale 1	Unit: Minutes (min), Range: 1 to 1440 mins Value x 1 (e.g. 5 mins = 5)	W	5 min
6064	406065	Modbus TCP IP Keep Alive Time Out (1)		Unit: Minutes (min), Range: 1 to 1440 mins		
6065	406066	HRL Temperature	Signed Scale 100	Unit: °C/°F, Range: -40°C to 260°C or -40°F to 500°F, Value x 100 (e.g. 5°C = 500 or 10°F = 1000)	RO	0°C or 32°F

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writable	Default Value
6066	406067	HRL Humidity	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	RO	0% RH
6067	406068	Board Temperature	Unsigned Scale 100	Unit: °C/°F, Range: 0°C to 100°C or 32°F to 212°F Value x 100 (e.g. 5°C = 500 or 32°F = 3200)	RO	0°C or 32°F
6068	406069	Power Output Feedback Bias	Unsigned Scale 1000	Unit: V, Range: 0V to 10V Value x 1000 (e.g. 1V = 1000)	W	0V
6069	406070	Power Output Feedback Min	Unsigned Scale 1000	Unit: V, Range: 0V to 10V Value x 1000 (e.g. 1V = 1000)	W	0V
6070	406071	Power Output Feedback Max	Unsigned Scale 1000	Unit: V, Range: 0V to 10V Value x 1000 (e.g. 1V = 1000)	W	10V
6071	406072	Power Output Feedback	Unsigned Scale 100	Unit: %, Range: 0% to 100% Value x 100 (e.g. 10% = 1000)	RO	0%
6072	406073	Room RH Network Reading	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	W	0% RH
6073	406074	Room RH Setpoint	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	W	40% RH
6074	406075	Room RH Unoccupied Setpoint	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	W	30% RH
6075	406076	Room RH Vacant Setpoint	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	W	20% RH
6076	406077	Room RH Demand Proportional Gain	Unsigned Scale 10	No Unit, Range: 1 to 200 Value x 10 (e.g. 10 = 100)	W	28.5
6077	406078	Room RH Demand Integral Time	Unsigned Scale 10	Unit: Seconds (sec), Range: 0 to 900 sec Value x 10 (e.g. 10 sec = 100)	W	0 sec
6078	406079	Room RH Demand Derivative Time	Unsigned Scale 10	Unit: Seconds (sec), Range: 0 to 60 sec Value x 10 (e.g. 10 sec = 100)	W	0 sec

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writable	Default Value
6079	406080	Room RH Demand	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	RO	0% RH
6080	406081	Room RH Demand Proportional Band (0)	Unsigned Scale 10	Unit: %, Range: 1% to 100% Value x 10 (e.g. 10% = 100)	W	5%
6081	406082	Room RH Demand Proportional Band (1)		Unit: %, Range: 1% to 100%		
6082	406083	Room Temperature Network Reading	Unsigned Scale 100	Unit: °C/°F, Range: -40°C to 260°C or -40°F to 500°F, Value x 100 (e.g. 5°C = 500 or 10°F = 1000)	W	0°C or 32°F
6083	406084	Room Temperature Setpoint (0)	Unsigned Scale 100	Unit: °C/°F, Range: 0°C to 40°C or 32°F to 104°F, Value x 100 (e.g. 5°C = 500 or 10°F = 1000)	W	22°C or 71.6°F
6084	406085	Room Temperature Setpoint (1)		Unit: °C/°F, Range: 0°C to 40°C or 32°F to 104°F		
6085	406086	Room Temperature Unoccupied Setpoint	Unsigned Scale 100	Unit: °C/°F, Range: 0°C to 40°C or 32°F to 104°F, Value x 100 (e.g. 5°C = 500 or 10°F = 1000)	W	24°C or 75.2°F
6086	406087	Room Temperature Vacant Setpoint	Unsigned Scale 100	Unit: °C/°F, Range: 0°C to 40°C or 32°F to 104°F, Value x 100 (e.g. 5°C = 500 or 10°F = 1000)	W	26°C or 78.8°F
6087	406088	Room Temperature Demand Proportional Gain (0)	Unsigned Scale 10	No Unit, Range: 1 to 200 Value x 10 (e.g. 10 = 100)	W	28.5
6088	406089	Room Temperature Demand Proportional Gain (1)		No Unit, Range: 1 to 200		
6089	406090	Room Temperature Demand Integral Time	Unsigned Scale 10	Unit: Seconds (sec), Range: 0 to 900 sec Value x 10 (e.g. 10 sec = 100)	W	0 sec
6090	406091	Room Temperature Demand Derivative Time	Unsigned Scale 10	Unit: Seconds (sec), Range: 0 to 60 sec Value x 10 (e.g. 10 sec = 100)	W	0 sec
6091	406092	Room Temperature Demand	Unsigned Scale 100	Unit: %, Range: 0% to 100% Value x 100 (e.g. 10% = 1000)	RO	0%
6092	406093	Room Temp Demand Proportional Band	Unsigned Scale 10	Unit: %, Range: 1% to 100% Value x 10 (e.g. 10% = 100)	W	5%

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writable	Default Value
6093	406094	RH Supply High Limit Network Reading	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	W	0% RH
6094	406095	RH Supply High Limit Setpoint	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	W	80% RH
6095	406096	RH Supply High Limit Unoccupied Setpoint	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	W	80% RH
6096	406097	RH Supply High Limit Vacant Setpoint	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	W	80% RH
6097	406098	RH Supply High Limit Proportional Gain	Unsigned Scale 10	No Unit, Range: 1 to 200 Value x 10 (e.g. 10 = 100)	W	28.5
6098	406099	RH Supply High Limit Integral Time	Unsigned Scale 10	Unit: Seconds (sec), Range: 0 to 900 sec Value x 10 (e.g. 10 sec = 100)	W	0 sec
6099	406100	RH Supply High Limit Derivative Time	Unsigned Scale 10	Unit: Seconds (sec), Range: 0 to 60 sec Value x 10 (e.g. 10 sec = 100)	W	0 sec
6100	406101	RH Supply High Limit Demand	Unsigned Scale 100	Unit: % RH, Range: 0% RH to 100% RH Value x 100 (e.g. 10% RH = 1000)	RO	0% RH
6101	406102	RH Supply High Limit Proportional Band (0)	Unsigned Scale 10	Unit: %, Range: 1% to 100% Value x 100 (e.g. 10% = 100)	RO	10%
6102	406103	RH Supply High Limit Proportional Band (1)		Unit: %, Range: 1% to 100%		
6103	406104	Temp Supply High Limit Network Reading	Signed Scale 100	Unit: °C/°F, Range: -40°C to 100°C or -40°F to 212°F, Value x 100 (e.g. 5°C = 500 or 10°F = 1000)	W	0°C or 32°F
6104	406105	Temp Supply High Limit Setpoint	Unsigned Scale 100	Unit: °C/°F, Range: 0°C to 40°C or 32°F to 104°F, Value x 100 (e.g. 5°C = 500 or 10°F = 1000)	W	15°C or 59°F
6105	406106	Temp Supply High Limit Unoccupied Setpoint	Unsigned Scale 100	Unit: °C/°F, Range: 0°C to 40°C or 32°F to 104°F, Value x 100 (e.g. 5°C = 500 or 10°F = 1000)	W	17°C or 62.6°F
6106	406107	Temp Supply High Limit Vacant Setpoint	Unsigned Scale 100	Unit: °C/°F, Range: 0°C to 40°C or 32°F to 104°F, Value x 100 (e.g. 5°C = 500 or 10°F = 1000)	W	16°C or 60.8°F

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writable	Default Value
6107	406108	Temp Supply High Limit Proportional Gain	Unsigned Scale 10	No Unit, Range: 1 to 200 Value x 10 (e.g. 10 = 100)	W	28.0
6108	406109	Temp Supply High Limit Integral Time	Unsigned Scale 10	Unit: Seconds (sec), Range: 0 to 900 sec Value x 10 (e.g. 10 sec = 100)	W	0 sec
6109	406110	Temp Supply High Limit Derivative Time	Unsigned Scale 10	Unit: Seconds (sec), Range: 0 to 60 sec Value x 10 (e.g. 10 sec = 100)	W	0 sec
6110	406111	Temp Supply High Limit Demand	Unsigned Scale 100	Unit: %, Range: 0% to 100% Value x 100 (e.g. 10% = 1000)	RO	0%
6111	406112	Temp Supply High Limit Proportional Band	Unsigned Scale 10	Unit: %, Range: 1% to 100% Value x 100 (e.g. 10% = 100)	RO	10%
6112	406113	Control Network Demand	Unsigned Scale 100	Unit: %, Range: 0% to 100% Value x 100 (e.g. 10% = 1000)	W	0%
6113	406114	Control Network High Limit	Unsigned Scale 100	Unit: %, Range: 0% to 100% Value x 100 (e.g. 10% = 1000)	W	0%
6114	406115	User Demand	Unsigned Scale 100	Unit: %, Range: 0% to 100% Value x 100 (e.g. 10% = 1000)	RO	0%
6115	406116	Demand Low Dead Band (0)	Unsigned Scale 100	Unit: %, Range: 0% to 100% Value x 100 (e.g. 10% = 1000)	W	1%
6116	406117	Demand Low Dead Band (1)		Unit: %, Range: 0% to 100%		
6117	406118	Network Timeout (0)	Unsigned Scale 1	Unit: Seconds (sec), Range: 1 to 900 sec Value x 1 (e.g. 10sec = 10)	W	900 sec
6118	406119	Network Timeout (1)		Unit: Seconds (sec), Range: 1 to 900 sec		
6119	406120	System Steam Capacity	Unsigned Scale 10	Unit: kg/hr or lb/hr, Range: 0 to 3000 kg/hr or 0 to 6614 lb/hr Value x 10 (e.g. 10kg/hr = 100 or 10lb/hr = 100)	RO	0 kg/hr or 0 lb/hr
10000	410001	Air Flow	Unsigned Scale 1	0 = Closed 1 = Open	RO	Closed

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writable	Default Value
10001	410002	Supply High Limit	Unsigned Scale 1	0 = Closed 1 = Open	RO	Closed
10002	410003	Interlock	Unsigned Scale 1	0 = Closed 1 = Open	RO	Closed
10003	410004	Binary External Demand	Unsigned Scale 1	0 = 0% 1 = 100%	RO	0%
10004	410005	Water Leak Detection	Unsigned Scale 1	0 = Ok 1 = Leak	RO	Ok
10005	410006	RS485 Interface	Unsigned Scale 1	0 = No 1 = Yes	RO	No
10006	410007	Ethernet Interface	Unsigned Scale 1	0 = No 1 = Yes	RO	No
10007	410008	Relay Fuse	Unsigned Scale 1	0 = Normal 1 = Blown Fuse	RO	Normal
10008	410009	Control PCB Fuse	Unsigned Scale 1	0 = Normal 1 = Open Fuse	RO	Normal
11000	411001	Alarm Warning Relay	Unsigned Scale 1	0 = Off 1 = On	RO	Off
11001	411002	Service Warning Relay	Unsigned Scale 1	0 = Off 1 = On	RO	Off
11002	411003	Water Supply Valve	Unsigned Scale 1	0 = Off 1 = On	RO	Off
11003	411004	Drain Valve	Unsigned Scale 1	0 = Off 1 = On	RO	Off
11004	411005	Circulation Pump	Unsigned Scale 1	0 = Off 1 = On	RO	Off

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writable	Default Value
11005	411004	Alarm LED	Unsigned Scale 1	0 = Off 1 = On	RO	Off
11006	411005	Power LED	Unsigned Scale 1	0 = Off 1 = On	RO	Off
11007	411008	Buzzer	Unsigned Scale 1	0 = Off 1 = On	RO	Off
12000	412001	Network Control State	Unsigned Scale 1	0 = Normal 1 = Fault	W	Normal
12001	412002	Float Switch	Unsigned Scale 1	0 = Inactive 1 = Active	RO	Inactive
12002	412003	Water Treatment Service Due	Unsigned Scale 1	0 = No 1 = Yes	RO	No
12003	412004	Service Due	Unsigned Scale 1	0 = Not Allowed 1 = Allowed	W	Not Allowed
12004	412005	Run While Water Service Alarm	Unsigned Scale 1	0 = Not Allowed 1 = Allowed	W	Not Allowed
12005	412006	Startup Line Rinse	Unsigned Scale 1	0 = Off 1 = On	W	Off
12006	412007	Run While Service Alarm	Unsigned Scale 1	0 = Not Allowed 1 = Allowed	W	Allowed
12007	412008	HRL Lock Setpoint	Unsigned Scale 1	0 = Unlock 1 = Lock	W	Unlock
12008	412009	Notify Alarm	Unsigned Scale 1	0 = Off 1 = On	W	Off
12009	412010	Notify Warning	Unsigned Scale 1	0 = Off 1 = On	W	Off

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writable	Default Value
12010	412011	Notify App Msg	Unsigned Scale 1	0 = Off 1 = On	W	Off
15000	415001	System Power State	Unsigned Scale 1	0 = Off 1 = On	RO	Off
15001	415002	System Log Verbose Level	Unsigned Scale 1	0 = None 1 = Emergency 2 = Alert 3 = Critical 4 = Error 5 = Warning 6 = Notice 7 = Info 8 = Debug	W	Debug
15002	415003	Modbus Server Units	Unsigned Scale 1	0 = Metric 1 = Imperial	W	Metric
15003	415004	Control Signal Type	Unsigned Scale 1	0 = 0-10Vdc 1 = 2-10Vdc 2 = 4-20mA 3 = 0-20mA	W	0-10Vdc
15004	415005	Control Signal Type	Unsigned Scale 1	0 = 0-10Vdc 1 = 2-10Vdc 2 = 4-20mA 3 = 0-20mA	W	0-10Vdc
15005	415006	Room RH Signal Type	Unsigned Scale 1	0 = 0-10Vdc 1 = 2-10Vdc 2 = 4-20mA 3 = 0-20mA	W	0-10Vdc
15006	415007	Room Temperature Signal Type	Unsigned Scale 1	0 = 0-10Vdc 1 = 2-10Vdc 2 = 4-20mA 3 = 0-20mA	W	0-10Vdc
15007	415008	Supply RH Signal Type	Unsigned Scale 1	0 = 0-10Vdc 1 = 2-10Vdc 2 = 4-20mA 3 = 0-20mA	W	0-10Vdc
15008	415009	Supply Temperature Signal Type	Unsigned Scale 1	0 = 0-10Vdc 1 = 2-10Vdc 2 = 4-20mA 3 = 0-20mA	W	0-10Vdc
15009	415010	State	Unsigned Scale 1	0 = Off 1 = Idle 2 = LineRinse 3 = Filling 4 = Draining 5 = Running 6 = Alarm 7 = Drying	RO	Off

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts	Writable	Default Value
15010	415011	System Alarm	Unsigned Scale 1	0 = Normal 1 = DrainTimeout 2 = FillTimeout 3 = WaterLeak 4 = FanDefect	RO	Normal
15011	415012	Recirculation Request	Unsigned Scale 1	0 = None 1 = ResetAlarms 2 = Drain 3 = ResetServCnt 4 = ResetWtrServCnt 5 = Filling	W	None
15012	415013	DirectFeed Request	Unsigned Scale 1	0 = None 1 = ResetAlarms 3 = ResetServCnt 4 = ResetWtrServCnt	W	None
15013	415014	Fan Request	Unsigned Scale 1	0 = Off 1 = Default 2 = On	W	Default
15014	415015	Pump Request	Unsigned Scale 1	0 = Off 1 = Default 2 = On	W	Default
15015	415016	Water Supply Request	Unsigned Scale 1	0 = Off 1 = Default 2 = On	W	Default
15016	415017	Control Profile	Unsigned Scale 1	0 = ExternAnalog 1 = ExternNetwork 2 = InternHumAnalog 3 = InternHumNetwork 4 = InternCoolAnalog 5 = InternCoolNetwork 6 = HRLHum 7 = HRLCool 8 = Custom	W	ExternAnalog
15017	415018	Modulating High Limit Profile	Unsigned Scale 1	0 = Disabled 1 = ExternAnalog 2 = ExternNetwork 3 = InternHumAnalog 4 = InternHumNetwork 5 = InternCoolAnalog 6 = InternCoolNetwork 7 = Custom	W	Disabled
15018	415019	Occupancy State	Unsigned Scale 1	0 = Occupied 1 = Unoccupied 2 = Vacant 3 = Off	RO	Occupied
15019	415020	Room RH Source	Unsigned Scale 1	0 = None 1 = RoomRH 2 = Network 3 = HRL	W	None
15020	415021	Room RH Setpoint Source	Unsigned Scale 1	0 = None 1 = Internal 2 = ControlInput	W	None

Protocol Base	Holding Register	Description	Data Type	Units, Limits, State Texts		Writable	Default Value
15021	415022	Room Temperature Source	Unsigned Scale 1	0 = None 1 = RoomTemp	2 = Network 3 = HRL	W	None
15022	415023	Room Temperature Setpoint Source	Unsigned Scale 1	0 = None 1 = Internal	2 = ControllInput	W	None
15023	415024	RH Supply High Limit Reading Source	Unsigned Scale 1	0 = None 1 = SupplyHLRH	2 = Network	W	None
15024	415025	RH Supply High Limit Setpoint Source	Unsigned Scale 1	0 = None 1 = Internal	2 = ControllInput	W	None
15025	415026	Temp Supply High Limit Reading Source	Unsigned Scale 1	0 = None 1 = SupplyHLTemp	2 = Network	W	None
15026	415027	Temp Supply High Limit Setpoint Source	Unsigned Scale 1	0 = None 1 = Internal	2 = ControllInput	W	None
15027	415028	Control Demand Source	Unsigned Scale 1	0 = None 1 = ControllInput	2 = RoomDemand 3 = Network	W	ControllInput
15028	415029	Control High Limit Source	Unsigned Scale 1	0 = None 1 = ControllInput	2 = RHSupplyHLDemand 3 = Network 4 = TempSupplyHLDemand	W	None
15029	415030	Control Cutout State	Unsigned Scale 1	0 = Off 1 = Normal 2 = LowLimit	3 = HighLimit 4 = NoAirFlow 5 = Interlock	RO	Off



neptronic®

400 Lebeau blvd, Montreal, Qc, H4N 1R6, Canada

www.neptronic.com

Toll free in North America: 1-800-361-2308

Tel.: (514) 333-1433

Fax: (514) 333-3163

Customer service fax: (514) 333-1091

Monday to Friday: 8:00am to 5:00pm (Eastern time)